



NOTES:

1. DISTANCE BETWEEN SCORE LINES NOT TO EXCEED 5' IN LONGITUDINAL & TRAVERSE DIRECTION IN SIDEWALK.
2. 1/4" TRANSVERSE EXPANSION JOINTS AT 20' INTERVAL FOR SIDEWALK.
3. 1/4" TRANSVERSE EXPANSION JOINTS AT 60' INTERVAL FOR CURB & GUTTER.
4. EXPANSION JOINTS IN SIDEWALK TO BE ADJACENT TO EXPANSION JOINTS IN CURB & GUTTER.
5. ALL EXPANSION JOINTS SHALL EXTEND COMPLETELY THROUGH CONCRETE BOTH VERTICALLY AND HORIZONTALLY
6. SIDEWALK TO HAVE 1" SCORE AT 5' INTERVALS.
7. SIDEWALK TO HAVE 1" MIN. - 2" MAX. OF SAND BEDDING
8. CURB & GUTTER TO HAVE 1" DEEP SCORE @ 10' INTERVALS



DEPARTMENT OF CITY SERVICES

STANDARD DETAIL 103

APPROVED

DATE

Sidewalk
Curb & Gutter