


FOR EXISTING SERVICE
 FOR 1" SERVICE USE JONES J1965W
 OR McDONALD 4602BF.
 OR CITY APPROVED EQUAL

FOR NEW SERVICE
 BALL ANGLE METER STOP
 FOR 1" SERVICE USE FORD
 BA23-444W-1" OR McDONALD
 4602B-1" OR CITY APPROVED EQUAL

CORPORATION STOP—
 FORD BALLCORP FB700 OR
 CITY APPROVED EQUAL.

NOTES:

1. 1" SERVICES SHALL BE COPPER TYPE "K" SOFT.
2. SPLICES IN THE SERVICE LINE ARE TO BE AVOIDED; BUT ALLOWED, THEY SHALL BE MADE USING THREADED OR FLARED CONNECTIONS.



1" WATER SERVICE
 MAIN CONNECTION

CHRISTY		
METER SIZE	MODEL NO.	LID TYPE *
1"	B 16	"D"

* WITH 1 3/4" HOLE / TRPL



DEPARTMENT OF CITY SERVICES

STANDARD DETAIL 405

 APPROVED DATE

Water Service 1"
 Main Connection