



LEGEND

- (G) — GAS
- (P) — ELECT. PRIMARIES
- (S) — ELECT. SECONDARIES
- (T) — TELEPHONE
- (TV) — TELEVISION

- * — INCREASE TO 30" IN STREET AREA
- ** — INCREASE TO 48" IN STREET AREA

NOTE: SEPARATION MAY BE REDUCED TO NOT LESS THAN 6" WHEN NECESSARY, INSTEAD OF INCREASING TRENCH WIDTH.

TYPICAL SIDEWALK & STREET JOINT TRENCH CONFIGURATIONS

JOINT TRENCH OCCUPANCY GUIDE

Sect.	(G)	(P)	(S)	(T)	(TV)	Fig.
A	X	X	12" Trench Width			1
B	X	X	X	12" Trench Width		1
C	X	X	X	X		1
D	X	X		X		1
E	X		X	12" Trench Width		1
F	X		X	X		2
G	X	X			X	1
H	X		X		X	2
I	X			X		1

Sect.	(G)	(P)	(S)	(T)	(TV)	Fig.
J	X			X	X	1
K	X				X	1
L		X	X	36" Min. Cover		3
M		X	X	X		3
N		X		X		3
P		X		X	X	3
Q		X	X		X	3
R		X			X	3
S			X	X		4

Sect.	(G)	(P)	(S)	(T)	(TV)	Fig.
T			X		X	4
U				X	X	4
V	X	X	X	X	X	1
W	X		X	X	X	2
X		X	X	X	X	3
Y			X	X	X	4



DEPARTMENT OF CITY SERVICES

STANDARD DETAIL 503

APPROVED

DATE

Joint Trench Configurations