



POLES SHALL BE ANY APPROVED POLE MEETING CALTRANS SPECIFICATION TYPE 15.

LUMINAIRE SHALL BE ANY APPROVED LUMINAIRE MEETING CALTRANS SPECIFICATIONS FOR H.P.S. TYPE III

ALL LUMINAIRE SHALL BE GENERAL ELECTRIC ROADWAY TYPE (COBRA HEAD) WITH THE LUMINAIRE INSTALLED WITH OPERATIONAL PHOTOCELLS FACING NORTH.

THE REFRACTOR SHALL HAVE H.P.S. TYPE III LIGHT DISTRIBUTION PATTERN EXCEPT WHERE DIRECTED BY THE CITY ENGINEER. ALL LUMINAIRE SHALL BE HIGH PRESSURE SODIUM.

LUMINAIRE SHALL HAVE MULTIPLE VOLTAGE BALASTS.

LUMINAIRE	
TYPE	WATTAGE
H.P.S.	70
H.P.S.	100
H.P.S.	150
H.P.S.	200



DEPARTMENT OF CITY SERVICES

\_\_\_\_\_  
APPROVED                      DATE

STANDARD DETAIL 704

**Street Light  
Luminaire**